



Ref. Certif. No.

SG PSB-LE-06396

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	Electronic controlgear for LED modules (24V Constant Voltage LED Power Supply)
Name and address of the applicant	Inventronics GmbH Parkring 31-33 85748 Garching by Munich GERMANY
Name and address of the manufacturer	Inventronics GmbH Parkring 31-33, 85748 Garching by Munich, GERMANY
Name and address of the factory	
Ratings and principal characteristics	Rated Input Voltage: 220-240V~ or 176-250Vdc Rated Frequency: 50/60Hz [for 220-240VAC] or 0Hz [for 176-250VDC] Rated Input Current: See test report for details Rated Output: See test report for details Protection against Electric Shock: Class I; SELV Degree of Protection: IP67 Method of Installation: Independent Type of Output: Constant voltage type ta: -30...55°C tc: See test report for details
Model/type Ref.	OT 100/220-240/24 DIM P; OT 100/220-240/24 P; OT 130/220-240/24 DIM P; OT 130/220-240/24 P; OT 250/220-240/24 DIM P; OT 250/220-240/24 P
A sample of the product was tested and found to be in conformity with	IEC 61347-1:2015 IEC 61347-1:2015/AMD1:2017 IEC 61347-2-13:2014 IEC 61347-2-13:2014/AMD1:2016
as shown in the Test Report Ref. No. which forms part of this certificate	211-901543-000

Page 1 of 2

This CB Test Certificate is issued by the National Certification Body

CBS 120825 0112 Rev. 00

Date, 2024-12-18

(Taylor Yao)

TÜV SÜD PSB Pte Ltd 15 International Business Park TÜV SÜD @ IBP Singapore 609937



PSB Singapore



Ref. Certif. No.

SG PSB-LE-06396

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

Trademark / Brand (Image)

inventronics

Page 2 of 2

This CB Test Certificate is issued by the National Certification Body

CBS 120825 0112 Rev. 00

Date, 2024-12-18

(Taylor Yao)

TÜV SÜD PSB Pte Ltd 15 International Business Park TÜV SÜD @ IBP Singapore 609937



PSB Singapore