



中国国家强制性产品认证证书

证书编号：2025171002006317

认证委托人名称及地址
广州英飞特科技有限公司

广东省广州市番禺区钟村街福华路15号1105、1106、1107单元

生产者名称及地址
广州英飞特科技有限公司

广东省广州市番禺区钟村街福华路15号1105、1106、1107单元

生产企业名称及地址

产品名称和系列、型号、规格
LED模块用电子控制装置（LED控制装置，内装式，恒流输出，EL，定温热保护：1
10°C）

EM FIT 75/220-240/550 D CS L CCT（输出：350/400/500/550mA，66.3/71.4/76.
5/81.6W，90-216Vdc，U-OUT=250V；输入：220-240V，0/50/60Hz）等，详见附录，
输入均为：220-240V，0/50/60Hz。

产品标准和技术要求
GB/T19510.1-2023；GB/T19510.213-2023；GB/T17743-2021；GB17625.1-2022

上述产品符合《强制性产品认证实施规则》
（CNCA-C10-01：2014）的要求，特发此证
发证日期：2025年12月31日 有效期至：2030年12月30日

证书信息和有效性可扫描下方二维码或登录发证机构网站查验，
也可在认监委网站（www.cnca.gov.cn）查询。



广东质检中诚认证有限公司

签发：

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。
经中国合格评定国家认可委员会认可CNAS C049-P





CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

Certificate No.: 2025171002006317

NAME AND ADDRESS OF THE APPLIANT

Inventronics Guangzhou Technology Ltd.

Unit 1105, 1106 and 1107, No. 15 Fuhua Road, Zhongcun Street, Panyu District, Guangzhou City,
Guangdong Province, R.P. China.

NAME AND ADDRESS OF THE MANUFACTURER

Inventronics Guangzhou Technology Ltd.

Unit 1105, 1106 and 1107, No. 15 Fuhua Road, Zhongcun Street, Panyu District, Guangzhou City,
Guangdong Province, R.P. China.

NAME AND ADDRESS OF THE FACTORY

NAME, MODEL AND SPECIFICATION

Electronic Controlgear For LED Modules (LED Driver, Built-in, Constant Current
Mode, EL, Temperature Declared Thermally Protected: 110°C)

EM FIT 75/220-240/550 D CS L CCT (Output:350/400/500/550mA, 66.3/71.4/76.5/81.6W,
90-216Vdc, U-OUT=250V; Input:220-240V, 0/50/60Hz) etc, see the appendix. 220-240V, 0/50/60Hz.

STANDARD AND TECHNICAL REQUIREMENT FOR THE PRODUCTS

GB/T19510.1-2023; GB/T19510.213-2023; GB/T17743-2021; GB17625.1-2022

This is certified that the above mentioned products have qualified for the requirements of
implementation rules for product certification(REF NO. CNCA-C10-01: 2014)


Date of issue: Dec.31,2025

Date of expiry: Dec.30,2030

Information and validity of the certificate can be checked by scanning the QR code below or logging
in the website of the issuing certification body, or checked on the website of CNCA:www.cnca.gov.cn

Validity of this certificate is subject to positive result of the regular follow up inspection by issuing
certification body until the expiry date.

Guangdong Quality Testing CTC Certification Co., Ltd.

SIGNATURE: 

Validity of this certificate is subject to positive result of the regular
follow up inspection by issuing certification body until the expiry date.
Accredited by China National Accreditation Service for Conformity
Assessment CNAS C049-P





中国国家强制性产品认证证书

证书编号：2025171002006317

证书附页：第 1 页 共 2 页

序号	型号	输出电流 (mA)	输 出 电 压 (Vdc)	U-OUT= (V)	功率(W)	ta (°C)	tc (°C)
1	EM FIT 75/220-240/550 D CS L CCT	350	90-216	250	75.6	55	80
		400	90-188	250	75.2		
		500	90-150	250	75.0		
		550	90-136	250	74.8		
2	EM FIT 60/220-240/350 D CS L CCT	200	90-175	250	35.0	55	85
		250	90-175	250	43.8		
		300	90-175	250	52.5		
		350	90-175	250	61.3		
3	EM FIT 40/220-240/350 D CS L CCT	200	40-120	250	24.0	60	85
		250	40-120	250	30.0		
		300	40-120	250	36.0		
		350	40-120	250	42.0		
4	EM FIT 18/220-240/350 D CS L CCT	200	24-54	250	10.8	60	75
		250	24-54	250	13.5		
		300	24-54	250	16.2		
		350	24-54	250	18.9		
5	EM FIT 75/220-240/550 D CS L	350	90-216	250	75.6	55	80
		400	90-188	250	75.2		
		500	90-150	250	75.0		
		550	90-136	250	74.8		
6	EM FIT 60/220-240/350 D CS L	200	90-175	250	35.0	55	85
		250	90-175	250	43.8		
		300	90-175	250	52.5		
		350	90-175	250	61.3		

本页为证书附页，应与证书主页同时使用。

广东质检中诚认证有限公司
信息查验说明见证书页



中国国家强制性产品认证证书

证书编号：2025171002006317

证书附页：第 2 页 共 2 页

7	EM FIT 40/220-240/350 D CS L	200	40-120	250	24.0	60	85
		250	40-120	250	30.0		
		300	40-120	250	36.0		
		350	40-120	250	42.0		
8	EM FIT 18/220-240/350 D CS L	200	24-54	250	10.8	60	75
		250	24-54	250	13.5		
		300	24-54	250	16.2		
		350	24-54	250	18.9		
9	EM FIT 75/220-240/550 D CS L G3	350	90-216	250	75.6	55	80
		400	90-188	250	75.2		
		500	90-150	250	75.0		
		550	90-136	250	74.8		
10	EM FIT 60/220-240/350 D CS L G3	200	90-175	250	35.0	55	85
		250	90-175	250	43.8		
		300	90-175	250	52.5		
		350	90-175	250	61.3		
11	EM FIT 40/220-240/350 D CS L G3	200	40-120	250	24.0	60	85
		250	40-120	250	30.0		
		300	40-120	250	36.0		
		350	40-120	250	42.0		
12	EM FIT 18/220-240/350 D CS L G3	200	24-54	250	10.8	60	75
		250	24-54	250	13.5		
		300	24-54	250	16.2		
		350	24-54	250	18.9		

输入均为：220-240V，0/50/60Hz。

本页为证书附页，应与证书主页同时使用。

广东质检中诚认证有限公司
信息查验说明见证书页